



**1** BASEMENT LEVEL - FLOOR PLAN  
 SCALE 1/4" = 1'-0"  
 3,228.70 SQ. FT.

**GENERAL NOTES:**

1. FIRE ALARM SYSTEM IS REQUIRED - VOICE ANNUNCIATION CORNS ARE NOT ACCEPTABLE PER NFPA 106-5.1, NFPA 72 AND OAC.
2. INTERIOR FINISH SHALL COMPLY WITH NFPA 106-5.1, F USING WOOD ON INTERIOR FINISH. IT SHALL BE FIRE RATED FROM THE FACTORY.
3. PAINT/ADHESIVE IS REQUIRED ON ALL DOORS WITH ANY O.L. OF 100 OR MORE.
4. PLANS WILL BE AVAILABLE ON CONSTRUCTION SITE.
5. THIS BUILDING WILL BE SPRAWLED.

